

FORM FOR PROPOSALS ON NFPA TECHNICAL COMMITTEE DOCUMENTS

NOTE: All Proposals Must Be Received By 5:00 P.M. EST/EDST On The Published Proposal Closing Date.

For further information on the standards-making process, please contact the Codes and Standards Administration at 617-984-7249, or visit www.nfpa.org/codes

For technical assistance, please call NFPA at 617-770-3000

FOR OFFICE USE ONLY

Log #: _____

Date Rec'd: _____

Please indicate in which format you wish to receive your ROP/ROC electronic paper download
(Note: In choosing the download option you intend to view the ROP/ROC from our Website; no copy will be sent to you.)

Date 4/5/06 Name Brad Shipp Tel. No. 301.519.9237

Company National Electronic Security Alliance (NESA) Email: bradshipp@4yoursolution.com

Street Address 10024 Vanderbilt Circle, # 4 City Rockville State MD Zip 20850

Please Indicate Organization Represented (if any) National Electronic Security Alliance (NESA)

1. a) NFPA Document Title Standard for the Installation of Electronic Premises Security Systems NFPA No. & Year 731-2006

b) Section/Paragraph Section 5.3.3.1

2. Proposal recommends: (check one) new text revised text deleted text

3. Proposal (include proposed new or revised wording, or identification of wording to be deleted): (Note: Proposed text should be in legislative format: i.e., use underscore to denote wording to be inserted (inserted wording) and strike-through to denote wording to be deleted (~~deleted wording~~).

5.3.3.1.9.3 Motion detectors shall include the following:

- (1) Two or more technologies
- (2) Microwave
- (3) Passive infrared (PIR)
- (4) Video Motion Detection (VMD).

~~5.3.3.1.10 Video Motion Detection (VMD). When activated, video motion detectors shall annunciate at the protected premises and display the captured image.~~

4. Statement of Problem and Substantiation for Proposal: (Note: State the problem that will be resolved by your recommendation; give the specific reason for your proposal including copies of tests, research papers, fire experience, etc. If more than 200 words, it may be abstracted for publication.)

Video Motion Detectors should be required to meet the same requirements as other motion detectors. There are occasions, such as cross zoning, where annunciation of a single event detected by a video motion detector may not be wise or appropriate. Some devices may analyze a video image but do not display the image or may require connection to a device by a technician to retrieve the image. The system designer and user should have the flexibility to choose an appropriate device to meet their need as long as the device complies with the general requirements for a motion detector

5. Copyright Assignment

a) I am the author of the text or other material (such as illustrations, graphs) proposed in this Comment.

b) Some or all of the text or other material proposed in this Comment was not authored by me. Its source is as follows: (please identify which material and provide complete information on its source) _____

I hereby grant and assign to the NFPA all and full rights in copyright in this Comment and understand that I acquire no rights in any publication of NFPA in which this Comment in this or another similar or analogous form is used. Except to the extent that I do not have authority to make an assignment in materials that I have identified in (b) above, I hereby warrant that I am the author of this comment and that I have full power and authority to enter into this assignment.

Signature (Required) _____

PLEASE USE SEPARATE FORM FOR EACH COMMENT • NFPA Fax: (617) 770-3500

Mail to: Secretary, Standards Council, National Fire Protection Association, 1 Batterymarch Park, P.O. Box 9101, Quincy, MA 02269
4/10/2006